Mothballing Checklist

Date_____ Project Manager_____

Moisture	DONE	N/A
Roof is watertight		
Gutters are clean and retain their proper pitch		
Downspout joints are intact		
Drains are unobstructed		
 Windows, doors, and their frames are in good condition 		
 Masonry walls are in good condition and seal out moisture 		
Wood siding is in good condition		
Site is properly graded for water run-off		
Vegetation has been cleared from around the building to avoid trapping moist	ure 📃	
Pests		
• Pests and nests have been removed from the building's interior and eaves		
Adequate screens are in place to guard against pests		
• The building has been inspected and treated for insects, rodents, and other pe	ests? 📃	
• Toxic droppings from bats and pigeons have been disposed of by a specialist		
Housekeeping		
• Trash, hazardous materials such as flammable liquids, poisons, and paints		
and canned goods that could freeze and burst have been removed		
Interior is broom-clean		
 Furnishings have been removed to a safe location 		
• Furnishings remaining in the building are properly protected from dust, pests,		
ultraviolet light, and other potentially harmful problems	_	
Significant architectural elements that have become detached from the buildir	ıg 🔛	
have been labeled and stored in a safe place		
There is a building file		
Security		
• Fire & police departments have been notified that the building will be mothbal	led 📃	
 Smoke and fire detectors are in working order 		
 Exterior doors and windows are securely fastened 		
 Plans are in place to monitor the building on a regular basis 		
 The keys to the building are in a secure but accessible location 		Ц
 The grounds are being kept from becoming overgrown 		
Utilities		
• Utility companies have disconnected, shut off, or fully inspected water, gas,		
and electric lines?		
 Water pipes have been drained and glycol has been added to traps The wiring is in a safe condition for any electricity left on 		H
Ventilation		
Steps have been taken to ensure proper ventilation of the building		\vdash
• Interior doors have been left open or removed for ventilation purposes		\vdash
 The building has been checked within the last 3 months for interior dampness and excessive humidity 		

Maintenance Log

Attach reports, notes, and comments



- termite and pest inspection & treatment as required
- exterior materials spot repair and touch up painting
- remove bird droppings or other stains from exterior
- check and update building file